

**SAMPLE REQUIREMENTS FOR CERTIFICATION OF NONPUBLIC
WATER SUPPLY SYSTEMS IN GLOUCESTER COUNTY**

Effective December 16, 2002

PARAMETER	MAXIMUM CONTAMINANT LEVEL
Microbiological	
Total coliform bacteria	Negative
Fecal coliform bacteria or E. coli if total coliform present	Negative
Inorganic Chemicals	MCL(ppm or mg/l)
Lead	0.015 (Action level)
Mercury	0.002
Nitrate	10 as N
Secondary Chemicals	MCL
PH	6.5-8.5
Iron	0.3 mg/l
Manganese	0.05 mg/l
Volatile Organic Compounds	EPA Method 502.2 or 524.2
Radiological (Effective for plans approved after March 15, 2003)	
Gross Alpha Activity	15 pCi/l (Treatment recommended above 5 pCi/l)